

In addition to Chazen's review comments dated June 27, 2016

- Label existing water mains (diameter, material, etc...)
- If private street, show easement for water main dedication to City
- Curb shut-offs located on private property limiting City's accessibility
- Water services beneath bioretention areas less than 5 ft. min. cover
- Water infrastructure to meet City Standards (Mueller hydrants/valves, RH-open, etc...)
- How will water valves be installed on active main w/out interruption to flow?
- Where is Gravel Diaphragm to be installed (Sheet 4) ?

Should you have any questions, etc., happy to discuss at your convenience.

Thanks.

Al

--

Albert Flick
Sr. Engineering Technician
City of Saratoga Springs
(518) 587-3550 ext. 2573

Confidentiality/Privilege Notice: This e-mail communication and any files transmitted with it contain privileged and confidential information from the City of Saratoga Springs and are intended solely for the use of the individual(s) or entity to which it has been addressed. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution, or taking any other action with respect to the contents of this message is strictly prohibited. If you have received this e-mail in error, please delete it and notify the sender by return e-mail. Thank you for your cooperation.
