



- NOTES:
1. TREE PROTECTION FENCING SHALL BE ERECTED AT THE EDGE OF THE CRITICAL ROOT ZONE OR BEYOND PRIOR TO THE START OF ANY CONSTRUCTION ACTIVITY.
 2. THE PROTECTED CRITICAL ROOT ZONE OF EACH TREE SHALL EXTEND FROM THE TRUNK A MINIMUM DISTANCE OF 1 FOOT FOR EACH INCH OF TRUNK DIAMETER, OR 6', WHICHEVER IS GREATER.
 3. FENCE SHALL BE MINIMUM 4' HIGH ON ALL SIDES, AND BE CONSTRUCTED OF CHAINLINK.
 4. FENCE SHALL BE SUPPORTED BY VERTICAL POSTS DRIVEN 2' (MIN) INTO THE GROUND. POSTS MUST AVOID MAJOR ROOTS, AND MUST BE SPACED NOT MORE THAN 10' APART.
 5. NO STOCKPILING OF MATERIALS, VEHICULAR TRAFFIC, OR STORAGE OF EQUIPMENT SHALL BE ALLOWED WITHIN THE THE FENCING. FENCING SHALL NOT BE MOVED OR REMOVED UNLESS APPROVED BY CITY FORESTER.
 6. FENCING SIGNAGE AS DETAILED MUST BE POSTED IN A VISUALLY PROMINENT LOCATION.

TREE PROTECTION FENCING DETAIL

N.T.S.

REVISED	DATE

CITY OF SARATOGA SPRINGS, NEW YORK

DWG No

STANDARD CONSTRUCTION
DETAIL

TREE PROTECTION

L-4